



## City of Santa Clara

Building Division  
1500 Warburton Ave.  
Santa Clara, CA 95050  
[www.santaclaraca.gov](http://www.santaclaraca.gov)

Building Division: 408-615-2440

Email: [Building@santaclaraca.gov](mailto:Building@santaclaraca.gov)

Permit Center: 408-615-2420

Email: [PermitCenter@santaclaraca.gov](mailto:PermitCenter@santaclaraca.gov)

Automated Inspection Scheduling System: 408-615-2400

# EXPEDITED SOLAR PHOTOVOLTAIC PERMITTING FOR ONE- AND TWO-FAMILY DWELLINGS CENTRAL STRING INVERTER SYSTEMS - 2016 CODES

This guide is for a streamlined permitting process for solar photovoltaic (PV) projects 10 kW in size or smaller, and includes information about submittal requirements for plan review, required fees and inspections.

## 1. Approval Requirements

- a) Planning department approval is required.
- b) A building permit is required.
- c) An electrical permit is required.
- d) A fire department permit is not required.
- e) Silicon Valley Power approval is required.

## 2. Submittal Requirements

- a) Completed permit application form. This permit application form can be downloaded at <http://santaclaraca.gov/government/departments/community-development>.
- b) Demonstrate compliance with the eligibility checklist for expedited permitting.
- c) A completed Standard Electrical Plan. The standard plan may be used for proposed solar installations 10 kW in size or smaller. This will include:
  - *Locations of main service or utility disconnect*
  - *Total number of modules, number of modules per string and the total number of strings*
  - *Make and model of inverter(s) and/or combiner box if used*
  - *One-line diagram of system*
  - *Specify grounding/bonding, conductor type and size, conduit type and size and number of conductors in each section of conduit*
  - *Equipment cut sheets including inverters, modules, AC and DC disconnects, combiners and racking system.*
  - *Labeling of equipment as required by CEC, Sections 690 and 705*
  - *Site diagram showing the arrangement of panels on the roof or ground, north arrow, lot dimensions and the distance from property lines to adjacent buildings/structures (existing and proposed)*
- d) A roof plan showing roof layout, PV panels and the following fire safety items: approximate location of roof access point, location of code-compliant access pathways, PV system fire classification and the locations of all required labels and markings. Examples of clear path access pathways are available in the State Fire Marshal Solar PV Installation Guide. <http://osfm.fire.ca.gov/pdf/reports/solarphotovoltaicguideline.pdf>.
- e) Complete expedited Structural Criteria along with required documentation.

For non-qualifying systems, provide structural drawings and calculations stamped and signed by a California-licensed Civil or Structural Engineer, along with the following information.

- The type of roof covering and the number of roof coverings installed
- Type of roof framing, size of members and spacing
- Weight of panels, support locations and method of attachment
- Framing plan and details for any work necessary to strengthen the existing roof structure
- Site-specific structural calculations
- Provide manufacturer documentation of the rack system, maximum allowable weight the system can support, attachment methods, and product evaluation information or structural design.

### 3. Plan Review

Permit applications can be submitted to the Building Division, City of Santa Clara Community Development Department, in person at 1500 Warburton Ave, Santa Clara, CA 95050. Permit applications utilizing the standard plan may be approved “over the counter.” Permits not approved “over the counter” will be reviewed in one to fifteen business days. Permits submitted on line cannot be an expedited review.

### 4. Fees

kW	Bld. Permit Fee	Plan Review Fee	Electrical Permit Fee	Seismic Fee	Bldg Standards Fee	Document Image Fee	Total
1.0 – 5.0	100.60	75.45	50.00	.50	1.00	30.00	256.90
5.01 – 10.0	156.60	117.40	50.00	.91	1.00	30.00	355.90

### 5. Inspections

Once all permits to construct the solar installation have been issued and the system has been installed, it must be inspected before final approval is granted for the solar system. On-site inspections can be scheduled by contacting the building division by our automated telephone system (408) 615-2400. Inspection requests are scheduled on a first-come first-served basis. If there is no other related work on the permit (such as a service upgrade) the first scheduled inspection can be the building and electrical final – menu codes 599 and 299 on the automated system.

Compliance with current smoke and carbon-monoxide alarm requirements is mandatory for all building permits.

Permit holders must be prepared to show conformance with all technical requirements in the field at the time of inspection. The inspector will verify that the installation is in conformance with applicable code requirements and with the approved plans.

The inspection checklist provides an overview of common points of inspection for which applicant should be prepared to show compliance. If not available, common checks include the following.

- Number of PV modules and model number match plans and specification sheets number match plans and specification sheets.
- Array conductors and components are installed in a neat and workman-like manner.
- PV array is properly grounded.
- Electrical boxes are accessible and connections are suitable for environment.
- Array is fastened and sealed according to attachment detail.
- Conductors ratings and sizes match plans.
- Appropriate signs are properly constructed, installed and displayed, including the following.
  - Sign identifying PV power source system attributes at DC disconnect
  - Sign identifying AC point of connection
  - Sign identifying switch for alternative power system
- Equipment ratings are consistent with application and installed signs on the installation, including the following.
  - Inverter has a rating as high as max voltage on PV power source sign.
  - DC-side overcurrent circuit protection devices (OCPDs) are DC rated at least as high as max voltage on sign.
  - Switches and OCPDs are installed according to the manufacturer’s specifications (i.e., many 600VDC switches require passing through the switch poles twice in a specific way).
  - Inverter is rated for the site AC voltage supplied and shown on the AC point of connection sign.
  - OCPD connected to the AC output of the inverter is rated at least 125% of maximum current on sign and is no larger than the maximum OCPD on the inverter listing label.
  - Sum of the main OCPD and the inverter OCPD is rated for not more than 120% of the bus bar rating.



## City of Santa Clara

Building Division  
1500 Warburton Ave.  
Santa Clara, CA 95050  
www.santaclaraca.gov

Building Division: 408-615-2440  
Email: Building@santaclaraca.gov  
Permit Center: 408-615-2420  
Email: PermitCenter@santaclaraca.gov  
Automated Inspection Scheduling System: 408-615-2400

### ELIGIBILITY CHECKLIST FOR EXPEDITED SOLAR PHOTOVOLTAIC PERMITTING FOR ONE- AND TWO-FAMILY DWELLINGS – 2016 CODES

#### GENERAL REQUIREMENTS

- |  |                            |                            |
|--|----------------------------|----------------------------|
| A. System size is 10 kW AC CEC rating or less  | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| B. The solar array is roof-mounted on one- or two-family dwelling or accessory structure | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| C. The solar panel/module arrays will not exceed the maximum legal building height       | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| D. Solar system is utility interactive and without battery storage                       | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| E. Permit application is completed and attached  | <input type="checkbox"/> Y | <input type="checkbox"/> N |

#### ELECTRICAL REQUIREMENTS

- |  |                            |                            |
|--|----------------------------|----------------------------|
| A. No more than four photovoltaic module strings are connected to each Maximum Power Point Tracking (MPPT) input where source circuit fusing is included in the inverter | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| 1) No more than two strings per MPPT input where source circuit fusing is not included   | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| 2) Fuses (if needed) are rated to the series fuse rating of the PV module  | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| 3) No more than one noninverter-integrated DC combiner is utilized per inverter  | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| B. For central inverter systems: No more than two inverters are utilized   | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| C. The PV system is interconnected to a single-phase AC service panel of nominal 120/220 Vac with a bus bar rating of 225 A or less                                      | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| D. The PV system is connected to the load side of the utility distribution equipment   | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| E. A Solar PV Standard Plan and supporting documentation is completed and attached   | <input type="checkbox"/> Y | <input type="checkbox"/> N |

#### STRUCTURAL REQUIREMENTS

- |   |                            |                            |
|---|----------------------------|----------------------------|
| A. A completed Structural Criteria and supporting documentation is attached (next page) | <input type="checkbox"/> Y | <input type="checkbox"/> N |
|---|----------------------------|----------------------------|

#### FIRE SAFETY REQUIREMENTS

- |  |                            |                            |
|--|----------------------------|----------------------------|
| A. Clear access pathways provided  | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| B. Fire classification solar system is provided  | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| C. All required markings and labels are provided   | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| D. A diagram of the roof layout of all panels, modules, clear access pathways and approximate locations of electrical disconnecting means and roof access points is completed and attached | <input type="checkbox"/> Y | <input type="checkbox"/> N |

#### Notes:

1. These criteria are intended for expedited solar permitting process.
2. If any items are checked NO, revise design to fit within Eligibility Checklist, otherwise permit application may go through standard process.

# Eligibility Checklist – Structural Criteria for Residential Flush-Mounted Solar Arrays

## 1. ROOF CHECKS

### A. Visual Review/Contractor's Site Audit of Existing Conditions:

- 1) Is the roof a single roof without a reroof overlay? ☐ Y ☐ N
- 2) Does the roof structure appear structurally sound, without signs of alterations or significant structural deterioration or sagging, as illustrated in Figure 1? ☐ Y ☐ N

### B. Roof Structure Data:

- 1) Measured roof slope (e.g. 6:12): \_\_\_\_\_:12
- 2) Measured rafter spacing (center-to-center): \_\_\_\_\_ inch
- 3) Type of roof framing (rafter or manufactured truss): ☐ Rafter ☐ Truss

## 2. SOLAR ARRAY CHECKS

### A. Flush-mounted Solar Array:

- 1) Is the plane of the modules (panels) parallel to the plane of the roof? ☐ Y ☐ N
- 2) Is there a 2" to 10" gap between underside of module and the roof surface? ☐ Y ☐ N
- 3) Modules do not overhang any roof edges (ridges, hips, gable ends, eaves)? ☐ Y ☐ N

### B. Do the modules plus support components weigh no more than:

- 4 psf for photovoltaic arrays or 5 psf for solar thermal arrays? ☐ Y ☐ N

### C. Does the array cover no more than half of the total roof area (all roof planes)?

☐ Y ☐ N

### D. Are solar support component manufacturer's project-specific completed worksheets, tables with relevant cells circled, or web-based calculator results attached?

☐ Y ☐ N

### E. Is a roof plan of the module and anchor layout attached? (see samples & last page)

☐ Y ☐ N

### F. Downward Load Check (Anchor Layout Check):

- 1) Proposed anchor horizontal spacing: \_\_\_\_\_' - \_\_\_\_\_"(ft-in)
- 2) Manufacturer specification for anchor spacing: \_\_\_\_\_' - \_\_\_\_\_"(ft-in)

### G. Wind Uplift Check (Anchor Fastener Check):

- 1) Anchor fastener data (provide cut sheets):
- a. Diameter of lag screw, hanger bolt or self-drilling screw: \_\_\_\_\_ inch
- b. Embedment depth of rafter: \_\_\_\_\_ inch
- c. Number of screws per anchor (typically one): \_\_\_\_\_
- d. Are 5/16" diameter lag screws embedded 2.5" into the rafters
- or does the anchor fastener have a different manufacturer specification? ☐ Y ☐ N

## 3. SUMMARY

- ☐ A. All items above are checked YES. No additional calculations are required.
- ☐ B. One or more items are checked NO. Attach project-specific drawings and calculations stamped and signed by a California-licensed civil or structural engineer.

Job Address: \_\_\_\_\_ Permit #: \_\_\_\_\_

Contractor/Installer: \_\_\_\_\_ License # & Class: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_ Phone #: \_\_\_\_\_



## City of Santa Clara

Building Division  
1500 Warburton Ave.  
Santa Clara, CA 95050  
www.santaclaraca.gov

Building Division: 408-615-2440  
Email: Building@santaclaraca.gov  
Permit Center: 408-615-2420  
Email: PermitCenter@santaclaraca.gov  
Automated Inspection Scheduling System: 408-615-2400

### SOLAR PV STANDARD PLAN – SIMPLIFIED CENTRAL/STRING INVERTER SYSTEMS FOR ONE- AND TWO-FAMILY DWELLINGS – 2016 CODES

SCOPE: Use this plan ONLY for electrical review of utility central/string inverter systems not exceeding a system AC inverter output rating of 10kW on the roof of a one- or two-family dwelling or accessory building. The specific structural and fire requirements are covered in other parts of the California Solar Permitting Guidebook. The photovoltaic system must interconnect to the load side of a single-phase AC service panel of nominal 120/240Vac with a bus bar rating of 225A or less. This plan is not intended for bipolar systems, hybrid systems or systems that utilize storage batteries, charge controllers, trackers, more than two inverters or more than one DC combiner (noninverter-integrated) per inverter. Systems must be in compliance with current California Building Standards Codes and local amendments of the authority having jurisdiction (AHJ). Other Articles of the California Electrical Code (CEC) shall apply as specified in 690.3. For systems beyond this scope or the criteria in this plan, consult the AHJ for details regarding comprehensive process.

MANUFACTURER'S SPECIFICATION SHEETS MUST BE PROVIDED for proposed inverters, modules, combiner/junction boxes, racking systems, and rapid shutdown system or equipment. Installation instructions for bonding and grounding equipment and rapid shutdown systems shall be provided, and local AHJs may require additional details. Listed and labeled equipment shall be installed and used in accordance with any instructions included in the listing or labeling (CEC 110.3). Equipment intended for use with PV system shall be listed for the PV application (CEC 690.4[B]).

Job Address: \_\_\_\_\_ Permit #: \_\_\_\_\_

Contractor/Engineer Name: \_\_\_\_\_ License # and Class: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_ Phone Number: \_\_\_\_\_

Total # of Inverters installed: \_\_\_\_\_ (If more than one inverter, complete and attach the "Supplemental Calculation Sheets" and the "Load Center Calculations" if a new load center is to be used.)

Inverter 1 AC Output Power Rating: \_\_\_\_\_ Watts

Inverter 2 AC Output Power Rating (if applicable): \_\_\_\_\_ Watts

Combined Inverter Output Power Rating: \_\_\_\_\_ ≤ 10,000 Watts

Location Ambient Temperatures (Check box next to which lowest expected temperature is used):

- 1) ☐ Lowest expected ambient temperature for the location ( $T_L$ ) = **Between -1° to -5° C**  
☐ Lowest expected ambient temperature for the location ( $T_L$ ) = **Between -6° to -10° C**  
Average ambient high temperature ( $T_H$ ) = 47° C  
Note: For a lower  $T_L$  or a higher  $T_H$ , use the Comprehensive Standard Plan

DC Information:

Module Manufacturer: _____		Model: _____
2) Module $V_{oc}$ (from module nameplate): _____ Volts	3) Module $I_{sc}$ (from module nameplate): _____ Amps	
4) Module DC output power under standard test conditions (STC) = _____ Watts (STC)		

## 5) DC Module Layout

Identify each source circuit (string) for inverter 1 shown on the roof plan with a Tag (e.g. A,B,C,...)

Number of modules per source circuit for inverter 1

Identify, by tag, which source circuits on the roof are to be paralleled (if none, put N/A)

		Combiner 1:
		Combiner 2:
Total number of source circuits for inverter 1:		

6) Are DC/DC Converters used? ☐ Yes ☐ No If No, skip to Step 7. If Yes enter info below.

DC/DC Converter Model #: \_\_\_\_\_

DC/DC Converter Max DC Input Voltage: \_\_\_\_\_ Volts

Max DC Output Current: \_\_\_\_\_ Amps

Max DC Output Current: \_\_\_\_\_ Volts

Max # of DC/DC Converters in an Input Circuit: \_\_\_\_\_

DC/DC Converter Max DC Input Power: \_\_\_\_\_ Watts

7) Maximum System DC Voltage — Use A1 or A2 for systems without DC/DC converters, and B1 or B2 with DC/DC Converters.

☐ A1. Module  $V_{oc}$  (STEP 2) = \_\_\_\_\_ x # in series (STEP 5) \_\_\_\_\_ x 1.12 (If  $-1 \leq T_L \leq -5^\circ\text{C}$ , STEP 1) = \_\_\_\_\_ V

☐ A2. Module  $V_{oc}$  (STEP 2) = \_\_\_\_\_ x # in series (STEP 5) \_\_\_\_\_ x 1.14 (If  $-6 \leq T_L \leq -10^\circ\text{C}$ , STEP 1) = \_\_\_\_\_ V

Table 1. Maximum Number of PV Modules in Series Based on Module Rated  $V_{oc}$  for 600 Vdc Rated Equipment (CEC 690.7)

Max. Rated Module $V_{oc}$ (*1.12) (Volts)	29.76	31.51	33.48	35.71	38.27	41.21	44.64	48.70	53.57	59.52	66.96	76.53	89.29
Max. Rated Module $V_{oc}$ (*1.14) (Volts)	29.24	30.96	32.89	35.09	37.59	40.49	43.86	47.85	52.63	58.48	65.79	75.19	87.72
Max # of Modules for 600 Vdc	18	17	16	15	14	13	12	11	10	9	8	7	6

Use for DC/DC converters. The value calculated below must be less than DC/DC converter max DC input voltage (STEP 6).

☐ B1. Module  $V_{oc}$  (STEP 2) = \_\_\_\_\_ x # of modules per converter (STEP 6) \_\_\_\_\_ x 1.12 (If  $-1 \leq T_L \leq -5^\circ\text{C}$ , STEP 1) = \_\_\_\_\_ V

☐ B2. Module  $V_{oc}$  (STEP 2) = \_\_\_\_\_ x # of modules per converter (STEP 6) \_\_\_\_\_ x 1.14 (If  $-6 \leq T_L \leq -10^\circ\text{C}$ , STEP 1) = \_\_\_\_\_ V

Table 2. Largest Module  $V_{oc}$  for Single-Module DC/DC Converter Configurations (with 80 V AFCI Cap) (CEC 690.7 and 690.11)

Max. Rated Module $V_{oc}$ (*1.12) (Volts)	30.4	33.0	35.7	38.4	41.1	43.8	46.4	49.1	51.8	54.5	57.1	59.8	62.5	65.2	67.9	70.5
Max. Rated Module $V_{oc}$ (*1.14) (Volts)	29.8	32.5	35.1	37.7	40.4	43.0	45.6	48.2	50.9	53.5	56.1	58.8	61.4	64.0	66.7	69.3
DC/DC Converter Max DC Input (Step #6) (Volts)	34	37	40	43	46	49	52	55	58	61	64	67	70	73	76	79

8) Maximum System DC Voltage from DC/DC Converters to Inverter — Only required if Yes in Step 6

Maximum System DC Voltage = \_\_\_\_\_ Volts

9) Sizing Source Circuit Conductors

Source Circuit Conductor Size = Min. #10 AWG copper conductor, 90° C wet (USE-2, PV Wire, XHHW-2, THWN-2, RHW-2)

For up to 8 conductors in roof-mounted conduit exposed to sunlight at least ½" from the roof covering (CEC 310)

Note: If > 8 conductors in the conduit or mounting height of lower than ½" from the roof, expedited plan not applicable.

10) Are PV source circuits combined prior to the inverter? ☐ Yes ☐ No

If No, use Single Line Diagram 1 and proceed to Step 13.

If Yes, use Single Line Diagram 2 with Single Line Diagram 4 and proceed to Step 12.

Is source circuit OCPD required? ☐ Yes ☐ No

Source circuit OCPD size (if needed):

11) Sizing PV Output Circuit Conductors — If a combiner box will NOT be used (Step 10),  
Output Circuit Conductor Size =

12) Inverter DC Disconnect

Does the inverter have an integrated DC disconnect? ☐ Yes ☐ No If Yes, proceed to step 14.

If No, the external DC disconnect to be installed is rated for \_\_\_\_\_ Amps (DC) and \_\_\_\_\_ Volts (DC)

13) Inverter Information

Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_

Max. Continuous AC Output Current Rating: \_\_\_\_\_ Amps

Integrated DC Arc-Fault Circuit Protection? ☐ Yes ☐ No (If No is selected, Expedited Plan not applicable)

Grounded or Ungrounded System? ☐ Grounded ☐ Ungrounded

AC Information:

14) Sizing Inverter Output Circuit Conductors and OCPD

Inverter Output OCPD rating = \_\_\_\_\_ Amps (Table 3)

Inverter Output Circuit Conductor Size = \_\_\_\_\_ AWG (Table 3)

Table 3. Minimum Inverter Output OCPD and Circuit Conductor Size									
Inverter Continuous Output Current Rating (Amps) (Step 14)	12	16	20	24	28	32	36	40	48
Minimum OCPD Size (Amps)	15	20	25	30	35	40	45	50	60
Minimum Conductor Size (AWG, 75° C, Copper)	14	12	10	10	8	8	6	6	6

### 15) Point of Connection to Utility

Only load side connections are permitted with this plan. Otherwise, use Comprehensive Standard Plan.

Is the PV OCPD positioned at the opposite end from input feeder location or main OCPD location? ☐ Yes ☐ No

If Yes, circle the Max Combined PV System OCPD(s) at 120% value as determined from Table 4.

If No, rating of main OCPD and Max Combined PV System OCPDs must be  $\leq$  bus bar rating.

If the panel has a “center-fed” main, the same rule can be used as when the breaker is at the opposite end from the main, provided there are loads between the main and PV breakers. (pre-approved AMM per Building Standards Commission recommendation)

Table 4. Maximum Combined Supply OCPDs Based on Bus Bar Rating (Amps) per CEC 705.12(D)(2)									
Bus Bar Rating	100	125	125	200	200	200	225	225	225
Main OCPD	100	100	125	150	175	200	175	200	225
Max Combined PV System OCPD(s) at 120% of Bus Bar Rating	20	50	25	60*	60*	40	60*	60*	45
Max Combined PV System OCPD(s) at 100% Bus Bar Rating	0	25	0	50	25	0	50	25	0

\*This value has been lowered to 60 A from the calculated value to reflect 10 kW AC size maximum.

Reduction of the main breaker is not permitted with this plan. Otherwise, use Comprehensive Standard Plan.



#### 16) Rapid Shutdown<sup>2</sup>

The rapid shutdown initiation device shall be labeled according to CEC 690.56(C), and its location shall be shown on the site plan drawing. The rapid shutdown initiation device may be the inverter output or input circuits' disconnecting means, the service main disconnect, or a separate device as approved by the AHJ. The disconnecting means shall be identified for the purpose, suitable for their environment, and listed as a disconnecting means. A single rapid shutdown initiation device shall operate all disconnecting means necessary to control conductors in compliance with CEC 690.12.

Note: Check with the AHJ regarding approval where field verification of reduction of voltage within the time required by CEC 690.12 is performed.

Rapid shutdown shall be provided as required by CEC 690.12 with one of the following methods (Select one):

- ☐ The inverter(s) is within 10 feet of the array, and the location of the inverter is such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. A remotely-controlled AC disconnecting means is required immediately adjacent to or as close as practicable to the inverters, and located within 10 feet of the array.
- ☐ The inverter(s) is within 10 feet of the array, and the location of the inverter is such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. Reduction of the voltage for the inverter output within the time required by CEC 690.12 shall be verified in the field, or the inverter output is listed to UL 1741 with rapid shutdown capability.
- ☐ Remotely-controlled DC disconnecting means are located within 10 feet of the PV array and DC input of the inverter(s), and the locations of the disconnecting means are such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. Reduction of the voltage for the inverter output within the time required by CEC 690.12 shall be verified in the field, or the inverter output is listed to UL 1741 with rapid shutdown capability.
- ☐ Remotely-controlled DC disconnecting means is located within 10 feet of the array at the DC input of inverter(s) connected to a module level DC-DC converter circuit where the DC-DC converter circuit meets the requirements for controlled conductors when disconnected from the inverter. Reduction of the voltage for the DC-DC converter output and the inverter output within the time required by CEC 690.12 shall be verified in the field, or the DC-DC converter output and the inverter output are listed to UL 1741 with rapid shutdown capability.
- ☐ A UL 1741-listed and identified inverter(s) with input and output rapid shutdown capability supplying module level DC-DC converter circuit where the DC-DC converter circuit meets the requirements for controlled conductors when disconnected from the inverter.
- ☐ A UL 1741-listed rapid shutdown system:

Manufacturer: \_\_\_\_\_

Testing Agency Name: \_\_\_\_\_

System Model Number: \_\_\_\_\_


System Components: \_\_\_\_\_

#### 17) Grounding and Bonding of Modules and Racking System (select one):

- ☐ Racking system listed to UL 2703 using modules identified in the listing.
- ☐ Other method subject to approval by City of Santa Clara

## Markings

Labels are required by articles 690 and 705 of the CEC and R324 of the California Residential Code. Not all of these labels are required at each project. Provide a plan showing which labels go at each of the locations.



Informational note: ANSI Z535.4 provides guidelines for the design of safety signs and labels for application to products. A phenolic plaque with contrasting colors between the text and background would meet the intent of the code for permanency. No type size is specified, but 20 point (3/8") should be considered the minimum.

CEC 705.12 requires a permanent plaque or directory denoting all electric power sources on or in the premises.

# Solar PV Standard Plan – Simplified

## Central/String Inverter System for One- and Two-Family Dwellings

### Refer to Step 16 for Rapid Shutdown details

TAG	DESCRIPTION	
1	SOLAR PV MODULE / STRING	<h3 style="margin: 0;">SINGLE-LINE DIAGRAM #1 – NO STRINGS COMBINED PRIOR TO INVERTER</h3> <p style="margin: 5px 0;">CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED:    <input type="checkbox"/> GROUNDED (INCLUDE GEC)    <input type="checkbox"/> UNGROUNDED</p> <p style="margin: 5px 0;">FOR UNGROUNDED SYSTEMS:</p> <ul style="list-style-type: none"> <li>- DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT</li> <li>- UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.</li> </ul>
2	DC/DC CONVERTERS INSTALLED?: YES / NO (IF YES, STEPS 6 & 8 REQUIRED)	
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO	
4	SEPARATE DC DISCONNECT INSTALLED?: YES / NO	
5	INTERNAL INVERTER DC DISCONNECT: YES / NO	
6	CENTRAL INVERTER	
7	LOAD CENTER INSTALLED?: YES / NO	
8	PV PRODUCTION METER INSTALLED?: YES / NO	
9	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO	
10	CONNECT TO INVERTER #2 (USE LINE DIAGRAM 2)	

\* Consult with your local AHJ and /or Utility

CONDUCTOR/CONDUIT SCHEDULE

TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/GEC:				
B					
	EGC/GEC:				
C					
	EGC/GEC:				
D					
	EGC/GEC:				

IF DC/DC CONVERTERS ARE USED, CHECK THE BOX BELOW THE CORRESPONDING CONFIGURATION

PARALLEL DC/DC CONVERTERS ON ONE SOURCE CIRCUIT (FIXED UNIT VOLTAGE DC/DC CONVERTERS)

☐

DC/DC CONVERTERS ARE ALL RUN IN SERIES (FIXED SOURCE CIRCUIT VOLTAGE DC/DC CONVERTERS)

☐

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE

# **Solar PV Standard Plan – Simplified** **Central/String Inverter System for One- and Two-Family Dwellings** **Refer to Step 16 for Rapid Shutdown details**

Δ TAG	DESCRIPTION
1	SOLAR PV MODULE / STRING
2	DC/DC CONVERTERS INSTALLED? YES / NO (IF YES, STEPS 6 & 8 REQUIRED)
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO
4	COMBINER BOX (STEPS 11 & 12 REQUIRED)
5	SEPARATE DC DISCONNECT?: YES / NO
6	INTERNAL INVERTER DC DISCONNECT: YES / NO
7	CENTRAL INVERTER
8	LOAD CENTER INSTALLED?: YES / NO
9	PV PRODUCTION METER INSTALLED?: YES / NO
10	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO
11	CONNECT TO INVERTER #2 (USE LINE DIAGRAM 4)


\* Consult with your local AHJ and /or Utility

## **SINGLE-LINE DIAGRAM #2 – COMBINING STRINGS PRIOR TO INVERTER**

CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED: ☐ GROUNDED (INCLUDE GEC) ☐ UNGROUNDED

FOR UNGROUNDED SYSTEMS:


- DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT
- UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.



COMBINER CONDUCTOR/CONDUIT SCHEDULE					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A1	USE-2 □ OR PV-WIRE □				
	EGC/GEC:				
B1					
	EGC/GEC:				
C					
	EGC/GEC:				
D					
	EGC/GEC:				
E					
	EGC/GEC:				

NON-COMBINED STRINGS CONDUCTOR/CONDUIT SCHEDULE (IF APPLICABLE)					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A2	USE-2 □ OR PV-WIRE □				
	EGC/GEC:				
B2					
	EGC/GEC:				

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE



## Supplemental Calculation Sheets for Inverter #2 (Only include if second inverter is used)

### DC Information:

Module Manufacturer: _____ Model: _____		
S2) Module $V_{oc}$ (from module nameplate): _____ Volts	S3) Module $I_{sc}$ (from module nameplate): _____ Amps	
S4) Module DC output power under standard test conditions (STC) = _____ Watts (STC)		
S5) DC Module Layout		
Identify each source circuit (string) for inverter 1 shown on the roof plan with a Tag (e.g. A,B,C,...)	Number of modules per source circuit for inverter 1	Identify, by tag, which source circuits on the roof are to be paralleled (if none, put N/A)
		Combiner 1:
		Combiner 2:
Total number of source circuits for inverter 1: _____		
S6) Are DC/DC Converters used? <input type="checkbox"/> Yes <input type="checkbox"/> No      If No, skip to Step S7. If Yes, enter info below.		
DC/DC Converter Model #: _____		DC/DC Converter Max DC Input Voltage: _____ Volts
Max DC Output Current: _____ Amps		Max DC Output Current: _____ Volts
Max # of DC/DC Converters in an Input Circuit: _____		DC/DC Converter Max DC Input Power: _____ Watts

S7) Maximum System DC Voltage — Use A1 or A2 for systems without DC/DC converters, and B1 or B2 with DC/DC Converters.

- ☐ A1. Module  $V_{oc}$  (STEP S2) = \_\_\_\_\_ x # in series (STEP S5) \_\_\_\_\_ x 1.12 (If  $-1 \leq T_L \leq -5^\circ\text{C}$ , STEP S1) = \_\_\_\_\_ V
- ☐ A2. Module  $V_{oc}$  (STEP S2) = \_\_\_\_\_ x # in series (STEP S5) \_\_\_\_\_ x 1.14 (If  $-6 \leq T_L \leq -10^\circ\text{C}$ , STEP S1) = \_\_\_\_\_ V

Table 1. Maximum Number of PV Modules in Series Based on Module Rated  $V_{oc}$  for 600 Vdc Rated Equipment (CEC 690.7)

Max. Rated Module $V_{oc}$ (*1.12) (Volts)	29.76	31.51	33.48	35.71	38.27	41.21	44.64	48.70	53.57	59.52	66.96	76.53	89.29
Max. Rated Module $V_{oc}$ (*1.14) (Volts)	29.24	30.96	32.89	35.09	37.59	40.49	43.86	47.85	52.63	58.48	65.79	75.19	87.72
Max # of Modules for 600 Vdc	18	17	16	15	14	13	12	11	10	9	8	7	6

Use for DC/DC converters. The value calculated below must be less than DC/DC converter max DC input voltage (STEP S6).

- ☐ B1. Module  $V_{oc}$  (STEP S2) = \_\_\_\_\_ x # of modules per converter (STEP S6) \_\_\_\_\_ x 1.12 (If  $-1 \leq T_L \leq -5^\circ\text{C}$ , STEP S1) = \_\_\_\_\_ V
- ☐ B2. Module  $V_{oc}$  (STEP S2) = \_\_\_\_\_ x # of modules per converter (STEP S6) \_\_\_\_\_ x 1.14 (If  $-6 \leq T_L \leq -10^\circ\text{C}$ , STEP S1) = \_\_\_\_\_ V

Table 2. Largest Module  $V_{oc}$  for Single-Module DC/DC Converter Configurations (with 80 V AFCI Cap) (CEC 690.7 and 690.11)

Max. Rated Module $V_{oc}$ (*1.12) (Volts)	30.4	33.0	35.7	38.4	41.1	43.8	46.4	49.1	51.8	54.5	57.1	59.8	62.5	65.2	67.9	70.5
Max. Rated Module $V_{oc}$ (*1.14) (Volts)	29.8	32.5	35.1	37.7	40.4	43.0	45.6	48.2	50.9	53.5	56.1	58.8	61.4	64.0	66.7	69.3
DC/DC Converter Max DC Input (Step 6) (Volts)	34	37	40	43	46	49	52	55	58	61	64	67	70	73	76	79

S8) Maximum System DC Voltage from DC/DC Converters to Inverter — Only required if Yes in Step S6  
Maximum System DC Voltage = \_\_\_\_\_ Volts

S9) Maximum Source Circuit Current

Is Module  $I_{sc}$  below 9.6 Amps (Step S3)? ☐ Yes ☐ No (If No, use Comprehensive Standard Plan)

S10) Sizing Source Circuit Conductors

Source Circuit Conductor Size = Min. #10 AWG copper conductor, 90° C wet (USE-2, PV Wire, XHHW-2, THWN-2, RHW-2)

For up to 8 conductors in roof-mounted conduit exposed to sunlight at least ½" from the roof covering (CEC 310)

Note: For over 8 conductors in the conduit or mounting height of lower than ½" from the roof, use Comprehensive Plan.

S11) Are PV source circuits combined prior to the inverter? ☐ Yes ☐ No

If No, use Single Line Diagram 1 and proceed to Step S13.

If Yes, use Single Line Diagram 2 with Single Line Diagram 4 and proceed to Step S12.

Is source circuit OCPD required? ☐ Yes ☐ No

Source circuit OCPD size (if needed): 15 Amps

S12) Sizing PV Output Circuit Conductors — If a combiner box will NOT be used (Step S11),  
Output Circuit Conductor Size = Min. #6 AWG copper conductor

S13) Inverter DC Disconnect

Does the inverter have an integrated DC disconnect? ☐ Yes ☐ No If Yes, proceed to Step S14.

If No, the external DC disconnect to be installed is rated for \_\_\_\_\_ Amps (DC) and \_\_\_\_\_ Volts (DC)

S14) Inverter Information

Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_

Max. Continuous AC Output Current Rating: \_\_\_\_\_ Amps

Integrated DC Arc-Fault Circuit Protection? ☐ Yes ☐ No (If No is selected, Comprehensive Standard Plan)

Grounded or Ungrounded System? ☐ Grounded ☐ Ungrounded

AC Information:

S15) Sizing Inverter Output Circuit Conductors and OCPD

Inverter Output OCPD rating = \_\_\_\_\_ Amps (Table 3)

Inverter Output Circuit Conductor Size = \_\_\_\_\_ AWG (Table 3)

Table 3. Minimum Inverter Output OCPD and Circuit Conductor Size									
Inverter Continuous Output Current Rating (Amps) (Step 14)	12	16	20	24	28	32	36	40	48
Minimum OCPD Size (Amps)	15	20	25	30	35	40	45	50	60
Minimum Conductor Size (AWG, 75° C, Copper)	14	12	10	10	8	8	6	6	6

## Load Center Calculations (Omit if a load center will not be installed for PV OCPDs)

S20) Load Center Output:

Calculate the sum of the maximum AC outputs from each inverter.

Inverter #1 Max Continuous AC Output Current Rating [STEP S14] \_\_\_\_\_ × 1.25 = \_\_\_\_\_ Amps

Inverter #2 Max Continuous AC Output Current Rating [STEP S14] \_\_\_\_\_ × 1.25 = \_\_\_\_\_ Amps

Total inverter currents connected to load center (sum of above) = \_\_\_\_\_ Amps

Conductor Size: \_\_\_\_\_ AWG

Overcurrent Protection Device: \_\_\_\_\_ Amps

Load center bus bar rating: \_\_\_\_\_ Amps

The sum of the ampere ratings of overcurrent devices in circuits supplying power to a bus bar or conductor shall not exceed 120 percent of the rating of the bus bar or conductor.

## Solar PV Standard Plan – Simplified Central/String Inverter System for One- and Two-Family Dwellings

TAG	DESCRIPTION	
1	SOLAR PV MODULE / STRING	<h3 style="margin: 0;">SINGLE-LINE DIAGRAM #3 – ADDITIONAL INVERTER FOR DIAGRAM #1</h3> <h4 style="margin: 0;">INVERTER # 2</h4> <p style="margin: 5px 0;">CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED:    <input type="checkbox"/> GROUNDED (INCLUDE GEC)    <input type="checkbox"/> UNGROUNDED</p> <p style="margin: 5px 0;">FOR UNGROUNDED SYSTEMS:</p> <ul style="list-style-type: none"> <li>- DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT</li> <li>- UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.</li> </ul>
2	DC/DC CONVERTERS INSTALLED?: YES / NO (IF YES, STEPS 6 & 8 REQUIRED)	
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO	
4	SEPARATE DC DISCONNECT INSTALLED?: YES / NO	
5	INTERNAL INVERTER DC DISCONNECT: YES / NO	
6	CENTRAL INVERTER	
7	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO	
8	TO LOAD CENTER ON LINE DIAGRAM 1	

\* Consult with your local AHJ and /or Utility

IF DC/DC CONVERTERS ARE USED, CHECK THE BOX BELOW THE CORRESPONDING CONFIGURATION

☐ PARALLEL DC/DC CONVERTERS ON ONE SOURCE CIRCUIT (FIXED UNIT VOLTAGE DC/DC CONVERTERS)

☐ DC/DC CONVERTERS ARE ALL RUN IN SERIES (FIXED SOURCE CIRCUIT VOLTAGE DC/DC CONVERTERS)

CONDUCTOR/CONDUIT SCHEDULE					
TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/GEC:				
B					
	EGC/GEC:				
C					
	EGC/GEC:				

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE



## Solar PV Standard Plan – Simplified

### Central/String Inverter System for One- and Two-Family Dwellings

△ TAG	DESCRIPTION	<b>SINGLE-LINE DIAGRAM #4 – ADDITIONAL INVERTER FOR DIAGRAM #2</b>																																																																																																
1	SOLAR PV MODULE / STRING	<div style="text-align: center;"><b>INVERTER # 2</b></div> <p>CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED:    <input type="checkbox"/> GROUNDED (INCLUDE GEC)    <input type="checkbox"/> UNGROUNDED</p> <p>FOR UNGROUNDED SYSTEMS:</p> <ul style="list-style-type: none"> <li>- DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT</li> <li>- UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.</li> </ul>																																																																																																
2	DC/DC CONVERTERS INSTALLED? YES / NO (IF YES, STEPS 6 & 8 REQUIRED)																																																																																																	
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO																																																																																																	
4	COMBINER BOX (STEPS 11 & 12 REQUIRED)																																																																																																	
5	SEPARATE DC DISCONNECT INSTALLED?: YES / NO																																																																																																	
6	INTERNAL INVERTER DC DISCONNECT: YES / NO																																																																																																	
7	CENTRAL INVERTER																																																																																																	
8	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO																																																																																																	
9	TO LOAD CENTER ON LINE DIAGRAM 3																																																																																																	
* Consult with your local AHJ and /or Utility																																																																																																		
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="6" style="text-align: center;">COMBINER CONDUCTOR/CONDUIT SCHEDULE</th> </tr> <tr> <th>□ TAG</th> <th>DESCRIPTION AND CONDUCTOR TYPE</th> <th>CONDUCTOR SIZE</th> <th>NUMBER OF CONDUCTORS</th> <th>CONDUIT/CABLE TYPE</th> <th>CONDUIT SIZE</th> </tr> </thead> <tbody> <tr> <td>A1</td> <td>USE-2 □ OR PV-WIRE □</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td>EGC/GEC:</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>B1</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td>EGC/GEC:</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>C</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td>EGC/GEC:</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>D</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td>EGC/GEC:</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>		COMBINER CONDUCTOR/CONDUIT SCHEDULE						□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE	A1	USE-2 □ OR PV-WIRE □						EGC/GEC:					B1							EGC/GEC:					C							EGC/GEC:					D							EGC/GEC:					<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="6" style="text-align: center;">NON-COMBINED STRINGS CONDUCTOR/CONDUIT SCHEDULE (IF APPLICABLE)</th> </tr> <tr> <th>□ TAG</th> <th>DESCRIPTION AND CONDUCTOR TYPE</th> <th>CONDUCTOR SIZE</th> <th>NUMBER OF CONDUCTORS</th> <th>CONDUIT/CABLE TYPE</th> <th>CONDUIT SIZE</th> </tr> </thead> <tbody> <tr> <td>A2</td> <td>USE-2 □ OR PV-WIRE □</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td>EGC/GEC:</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>B2</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td>EGC/GEC:</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table> <p style="font-size: small; text-align: center;">ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE</p>	NON-COMBINED STRINGS CONDUCTOR/CONDUIT SCHEDULE (IF APPLICABLE)						□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE	A2	USE-2 □ OR PV-WIRE □						EGC/GEC:					B2							EGC/GEC:				
COMBINER CONDUCTOR/CONDUIT SCHEDULE																																																																																																		
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE																																																																																													
A1	USE-2 □ OR PV-WIRE □																																																																																																	
	EGC/GEC:																																																																																																	
B1																																																																																																		
	EGC/GEC:																																																																																																	
C																																																																																																		
	EGC/GEC:																																																																																																	
D																																																																																																		
	EGC/GEC:																																																																																																	
NON-COMBINED STRINGS CONDUCTOR/CONDUIT SCHEDULE (IF APPLICABLE)																																																																																																		
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE																																																																																													
A2	USE-2 □ OR PV-WIRE □																																																																																																	
	EGC/GEC:																																																																																																	
B2																																																																																																		
	EGC/GEC:																																																																																																	

IF DC/DC CONVERTERS ARE USED, THEY ARE RUN IN SERIES (FIXED SOURCE CIRCUIT VOLTAGE DC/DC CONVERTERS)

# **SOLAR PV STANDARD PLAN**

**Roof Layout Diagram for One- and Two-Family Dwellings**

Items required: roof layout of all panels, modules, clear access pathways and approximate locations of electrical disconnecting means and roof access points.

